

### Minimum Size of the conductor

1 Main Earthing Grid	50 mm x 6 mm GI strip
2 CCTV Pole Structure	50 mm x 6 mm GI strip
3 UPS Neutral	50 mm x 6 <b>mm</b> GI strip
4 UPS Body, panels, console etc	50 mm x 6 mm GI strip
5 Junction Box	1 mm unarmoured FRLS Copper cable
Hardware	Specifications
1 Earth Pits	3043 standards with electrode minimum 3 meters Earthing Bus :- bus shall be typically 25mm wide and 6 mm thick of copper or 50 x 6 GI strip